Discussion of the paper "Composite steel-deck-reinforced concrete systems failing in shear-bond" by R.M. Schuster

Autor(en): **Johnson, R.P.**

Objekttyp: Article

Zeitschrift: IABSE congress report = Rapport du congrès AIPC = IVBH

Kongressbericht

Band (Jahr): 9 (1972)

PDF erstellt am: 23.05.2024

Persistenter Link: https://doi.org/10.5169/seals-9653

Nutzungsbedingungen

Die ETH-Bibliothek ist Anbieterin der digitalisierten Zeitschriften. Sie besitzt keine Urheberrechte an den Inhalten der Zeitschriften. Die Rechte liegen in der Regel bei den Herausgebern. Die auf der Plattform e-periodica veröffentlichten Dokumente stehen für nicht-kommerzielle Zwecke in Lehre und Forschung sowie für die private Nutzung frei zur Verfügung. Einzelne Dateien oder Ausdrucke aus diesem Angebot können zusammen mit diesen Nutzungsbedingungen und den korrekten Herkunftsbezeichnungen weitergegeben werden.

Das Veröffentlichen von Bildern in Print- und Online-Publikationen ist nur mit vorheriger Genehmigung der Rechteinhaber erlaubt. Die systematische Speicherung von Teilen des elektronischen Angebots auf anderen Servern bedarf ebenfalls des schriftlichen Einverständnisses der Rechteinhaber.

Haftungsausschluss

Alle Angaben erfolgen ohne Gewähr für Vollständigkeit oder Richtigkeit. Es wird keine Haftung übernommen für Schäden durch die Verwendung von Informationen aus diesem Online-Angebot oder durch das Fehlen von Informationen. Dies gilt auch für Inhalte Dritter, die über dieses Angebot zugänglich sind.

Ein Dienst der *ETH-Bibliothek* ETH Zürich, Rämistrasse 101, 8092 Zürich, Schweiz, www.library.ethz.ch

DISCUSSION LIBRE • FREIE DISKUSSION • FREE DISCUSSION

Discussion of the Paper "Composite Steel-Deck-Reinforced Concrete Systems Failing in Shear-Bond" by R.M. Schuster

Discussion de la contribution "Composite Steel-Deck-Reinforced Concrete Systems Failing in Shear-Bond" par R.M. Schuster

Diskussion des Beitrages "Composite Steel-Deck-Reinforced Concrete Systems Failing in Shear-Bond" von R.M. Schuster

R.P. JOHNSON England

Static and fatigue tests on steel-deck-reinforced concrete slabs similar to those reported by R.M. Schuster were carried out at Cambridge University, England, in 1970-71. It was found that ultimate strength of the composite slabs was strongly influenced by two variables not discussed in the present paper.

The first is the detail at the edge of the slab. If the outermost corrugation of the decking can separate from the slab due to transverse bending of the deck, then the longitudinal shear strength is less than when the free edge of the decking is embedded in the slab in some way. For example, the edge detail shown in Fig. 1 of the paper would perform better than that shown in Fig. 3. The effect is of course more significant in narrow laboratory specimens than it is in practice.

The second variable is the roughness of the dimples or corrugations provided in the inclined sides of the sheets. Measurements on sheets provided by one of the same suppliers that R.M. Schuster used showed that the dimple depths ranged from 0.6 mm to 1.1 mm. The mean depths for individual sheets were more uniform (0.79 to 0.97 mm), but it is likely that the variation is sufficient to influence the shear strength of composite plates in which these sheets are used.