

Problems found during the seismic design of structures and equipments of nuclear power plant

Autor(en): **Lazzeri, L. / Bozzo, F. / Filippi, G.**

Objektyp: **Article**

Zeitschrift: **IABSE reports of the working commissions = Rapports des commissions de travail AIPC = IVBH Berichte der Arbeitskommissionen**

Band (Jahr): **30 (1978)**

PDF erstellt am: **12.07.2024**

Persistenter Link: <https://doi.org/10.5169/seals-24199>

Nutzungsbedingungen

Die ETH-Bibliothek ist Anbieterin der digitalisierten Zeitschriften. Sie besitzt keine Urheberrechte an den Inhalten der Zeitschriften. Die Rechte liegen in der Regel bei den Herausgebern.

Die auf der Plattform e-periodica veröffentlichten Dokumente stehen für nicht-kommerzielle Zwecke in Lehre und Forschung sowie für die private Nutzung frei zur Verfügung. Einzelne Dateien oder Ausdrucke aus diesem Angebot können zusammen mit diesen Nutzungsbedingungen und den korrekten Herkunftsbezeichnungen weitergegeben werden.

Das Veröffentlichen von Bildern in Print- und Online-Publikationen ist nur mit vorheriger Genehmigung der Rechteinhaber erlaubt. Die systematische Speicherung von Teilen des elektronischen Angebots auf anderen Servern bedarf ebenfalls des schriftlichen Einverständnisses der Rechteinhaber.

Haftungsausschluss

Alle Angaben erfolgen ohne Gewähr für Vollständigkeit oder Richtigkeit. Es wird keine Haftung übernommen für Schäden durch die Verwendung von Informationen aus diesem Online-Angebot oder durch das Fehlen von Informationen. Dies gilt auch für Inhalte Dritter, die über dieses Angebot zugänglich sind.

PROBLEMS FOUND DURING THE SEISMIC DESIGN OF STRUCTURES AND
EQUIPMENTS OF A NUCLEAR POWER PLANT

L. LAZZERI, F. BOZZO, G. FILIPPI
(SAIGE SpA , GENOA- ITALY)

ABSTRACT

The aim of this paper is a review of the main points found during the analysis of a nuclear power plant from the seismic point of view .

The main points are :

- soil structure interaction
- modelling of structures
- static equivalent models
- floor response spectra
- piping analysis
- electrical cableways
- heavy components

1. INTRODUCTION

The seismic analysis of nuclear power stations structures and components is one of the main problems, the designer has to solve in order to assess the safety of the populations even in the case of extreme earthquakes events. The aim of this paper is a brief analysis of the different problems one has to face, from the soil-structure interaction to sample analysis of different equipments in a nuclear power station.

2. SOIL-STRUCTURE INTERACTION

As it is well known (see, as an example ref [1]) the soil structure interaction problem is of paramount importance in determining the response of the structures to the seismic excitation. The usual and simplest way of considering the soil-structure problem is by means of a set of springs, which model the stiffness of the ground surrounding the structure. This method, largely based on a method proposed by Whitman [2], [3], has been widely used in the past and it is quite satisfactory when the soil is relatively uniform and no large embedment is present. Different methods [4], [5], [6], [7] dealing with modifications and corrections of the original half space method have been proposed, however finite element methods (based on the use of the computer code FLUSH and subsequent modifications [8], [9], [10]) are available for an efficient evaluation of the soil-structure interaction phenomenon. A lot of papers was written to compare the different advantages of the two methods, however in this paper, the authors have simply decided to report their particular experience in this field.

The usual spring methods has large advantages in terms of cost and simplicity, so that many parametric analyses can be performed considering even a large spread of data regarding the soil characteristics [11] and is generally satisfactory. However, many cases exist where a good assessment of the phenomenon can be obtained by the use of the FLUSH code, as an example with relatively complicated soil profiles, with large embedment phenomena or when the so called building-soil-building phenomena may have importance. As far as this last aspect is concerned some runs have been performed in the case of neighbouring buildings on a relatively hard but comparatively not uniform soil (the modulus of elasticity ranging from 20000 to more than 100000 Kg/cm²). The first example is shown in fig.1, where two building of relatively similar weight and size have shown a coupled behaviour quite similar to the uncoupled one. The coupling phenomenon is definitively more easily discerned in the example in fig.2a, the response spectrum in fig.2b in one building clearly presents a peak corresponding to the eigenfrequency of the other building. However in this case too, while significant effects can be anticipated in terms of the response spectra, no large influence in the building accelerations was detected. Again this is quite possibly due to the relative resemblance of the two buildings, while the building-building interaction phenomenon should quite possibly be more important for small buildings near much heavier ones.

3. MODELLING OF STRUCTURES

A discussion of the techniques used in analyzing and modelling the civil structures of a nuclear power stations is given in reference [1]. In many cases, particularly for stiff buildings on very soft soils, a very simple model of the building (stick model) is adequate to predict the behaviour of the building [12]; a lumped masses model is used, the masses are generally placed at the floors levels with beam connections, representing the stiffness of the walls connecting subsequent floors. However for panels buildings (box type buildings) the stick model may be not quite adequate and for relatively stiff soil, where influence of the building stiffness may be important, finite elements model may be necessary. In fig.3a an example of a finite elements model is shown and the results of the dynamic analysis is shown in fig.3b; obviously enough the coupling of the panels vibrations with the over all building vibration, which is visible in the eigen frequency pattern in fig.3b, is not detectable with a stick model. On the other end box type buildings can be quite complicated and an efficient model can be very expensive due to its size, so that substructuring and condensing techniques are to be used.

4. STATIC EQUIVALENT MODELS

For obvious economical reasons the dynamic models are relatively of small size and their use can be not quite adequate to compute the inertial forces for the subsequent stresses evaluation. Again huge (thousands degrees of freedom) finite elements models have been used [12], but their use is very expensive so that simplificative assumptions have to be used. To test different methods some runs have been made by the authors and their colleagues in SAIGE [13][14]. In fig.4a a simplified model is shown; it has been loaded by constant inertial forces in the horizontal plane and by vertical forces on the floor simulating a rotation effect. The displacements pattern is shown in fig.4b,c. While the simplifications in the model may be relatively important (only the lower portion of the building has been modelled, while the influence of the stiffness of the upper portion may have some importance) some general conclusions may be drawn:

- the shear is absorbed only by the walls parallel to the direction of the seismic excitation and it is relatively constant in them
- the bending moment is not absorbed by the structure as a whole, rather the normal stresses are concentrated mainly in the corners or where two normal walls are present
- the floors are not rigid as regards the out of plane bending and are not consequently adequate to transfer the stresses from one end of the building to the other one
- some deformations take place even due to in plane forces, however this effect is much more limited than the previous ones, so that a relatively uniform shear stress distribution takes place

- the vertical forces consequent to rotational accelerations are taken directly by the floors where they are applied and transferred locally to the vertical frames.

Particularly for low and wide buildings the shears seem to be absolutely predominant and the floors are generally adequate to act as rigid frames so that the seismic shears are taken by the vertical walls between subsequent floors independently from the distributions over and under the connected floors. The behaviour is quite opposed to the one usually known as typical of 'shear type buildings' and represents consequently the other extreme.

However there are buildings where both bending and shears may play an important role so that finite elements models only can be used for a relatively exact evaluation of the seismic stresses.

5. FLOOR RESPONSE SPECTRA

As it is well known, the modelling of the structures is limited to the main components, while the minor ones are neglected. However there are many components (piping, valves, pumps, electrical components, etc.) which are important for the safety of the plant and whose seismic analysis has to be performed. For relatively light components it is comparatively accurate to assume that no feedback action takes place from the component, so that the seismic time history due to the earthquake and filtered by the building can be directly assumed by it. This procedure is generally known as 'calculating a floor response spectrum' and it is used even for relatively heavy components even if in this case the procedure may be relatively pessimistic [15]. Many techniques have been proposed using both stochastic [16] or semistochastic methods [17], [18]; the use of these methods has large advantages in terms of cost and time as they are based on the use of the response spectrum analyses for the buildings. On the other end time histories analyses have been proposed and used even if they are relatively expensive. The first problem to be solved is the generation of a time history compatible with the given ground response spectrum; starting with a paper by Nih Chien Tsai [19] techniques have been proposed [21] and an earthquake time history representation by means a Fourier series. Both the SIMQKE program [20] and a home-made program THAMS [22], [23] based on reference [21]. In fig.5 the time history compatible with the standard USA Regulatory Guide 1.60 is shown as generated by THAMS program is shown.

Much discussion has been made about the relative merits of the simplification and time history methods, it is the authors' opinion that the use of the time history methods are quite necessary in many cases (as an example whenever non linear techniques are necessary or when time histories are necessary as an example for tests on heavy machinery or electric components), however defects in the methods (lack in uniqueness in the solution, costs) may make the simplification ones preferable. As an example, in many cases, it is not quite necessary to know exactly the floor response spectrum rather it is important to know for which frequencies there is the so called peaks region (large amplifications

in the accelerations) and which is the minimum frequency for which the floor response spectrum is flat. In this cases the advantages of the simplified methods are obvious.

6. PIPING ANALYSIS

The seismic analysis of piping runs is one of the main tasks for the designer of a nuclear power system , due to the large numbers of components to be analyzed . It should be further mentioned that ASME 3 NB pipes generally have some problems concerning the thermal analysis and consequent fatigue evaluation, so that it is convenient to have pipings as flexible as possible ; obviously enough this necessity is contrary to the seismic one, as it is customary to have eigen frequencies higher than the peak zone ones in order to minimize the accelerations in the pipe [24] . Then the use of viscous or inertial snubbers has been found particularly useful in solving this problem . However the costs of these equipments is comparatively large so that there is a strong necessity for the limitation of their number , besides the dynamic analyses themselves are relatively expensive and time consuming so that some predesign criterion is very useful indeed [25] .

Some simple predesign criteria (based on a hypothetic independent behaviour of each span of pipe between successive supports) are used for the sizing of the snubbers and a preliminary evaluation of their collocation. Then a final dynamic analysis is performed for a final appraisal of the solution ; an example is given in ref. 5.

It should further mentioned that a huge number of piping in a nuclear power station do not have dilatation problems and their minor importance does not require particular dynamic analysis, hence the simplified analysis are particularly interesting . Two criteria are generally considered,

- each span is considered in an independent way so that the fundamental eigen frequency is larger than the one corresponding to the beginning of the flat region in the FRS ,
- the maximum stresses are very low so that the seismic excitation does not contribute to a substantial increase in the stresses.

7. ANALYSIS OF ELECTRICAL CABLEWAYS

Most of the safety related components are electromechanical, whose energy comes via electric wiring ; then they must be analyzed from a seismic point of view. The problem does not present substantial difficulty from a theoretical point of view, however the huge number of components to be analyzed represents a difficulty in itself. Normalization and the use of computerized procedures is then absolutely necessary in order to perform these analyses within reasonable time and costs. ASDIC [26] is an answer to these necessities; the code is capable of analyzing the support structures of cableways and electric wirings,

determining the maximum loads (dead load and seismic loads specified under the form of support structures) compatible with each geometric configuration (as an example see fig.6) Then the use of ASDIC together with a normalization makes these analyses quite easy.

8. ANALYSIS OF HEAVY COMPONENTS

The analysis of heavy components is a necessary step in assessing the safety of the plant from the seismic point of view . While many analyses have been performed for important mechanical components such as pressure vessels, pumps etc., few analyses have been reported about electrical equipments such as motors, alternators etc. From a theoretical point of view many problems seem to exist as relative displacements between the stators and rotors could cause heavy consequences on the normal service of the machinery. For this reason some analyses have been performed (see fig.7) on typical machinery by means of finite elements models (approximately 1000 degrees of freedom). The results have been quite good showing that the normal working necessities claim for heavy rigidity necessities, so that the machines are generally rigid . Partial vibrations of some panels might take place, without any loss of functionality of the machine itself. Besides no large relative displacements among the different parts of the structure take place as due to the seismic excitation, so that no large electrical problems are anticipated.

9. ACKNOWLEDGMENTS

The authors are greatly indebted with their colleagues in the Special Calculations Group of SAIGE without whose help all the described calculations could not have been performed.

REFERENCES

1. IAEA Standard on Seismic Analysis
2. Whitman Richart "Design procedures for dynamically loaded foundations J Soil Mechanics and Foundation division of ASME, Nov. 1967 SM6 Nov.1967
3. Biggs Whitman "Soils structure interaction in nuclear power plants 1 SMIRT Conference , Berlin 1971
4. Hall Morrone Soil structure interaction parameters for a nuclear containment vessel 2 SMIRT Conf. paper K2/6, Berlin 1973
5. Hadijan Luco Two - dimensional approximations to the three - dimensional soil - structure interaction problem. Nuclear Engineering and Design 31/2 1974
6. Luco Westmann "Dynamic response of circular footings - J. Engineering Mechanics Division of SAIGE EM-5 , 1971
7. Kausel Roesset "Soil structure interaction problems for nuclear containment structures ASCE - Power Division Specialty Conf. 1974 Denver

8. Lysmer Udaka Tsae Seed "FLUSH a computer program for approximate 3D analysis of soil-structure interaction problems" Rep. EERC 75-30, Nov.1975
9. Seed Lysmer "Soil structure interaction analysis by finite element methods State of the art" 4th SMIRT Conference St.Francisco paper K2/1 , 1977
10. Romo Organista, Lysmer , Seed "Finite Elements Random Vibration method for soil-structure interaction analysis" 4 SMIRT Conf. St.Francisco 1977, paper K2/3
11. Lazzeri Sano " Seismic analysis of the primary building of a BW reactor "V WCEE Conference , paper , Rome 1973
12. Bergeretto Giuliano Lazzeri "A complete analysis of a nuclear building to nuclear safety standards" paper J2/2, 3 SMIRT Conference , London 1975
13. Bozzo Lazzeri Internal SAIGE Report
14. Porfido Personal communications (Internal SAIGE Report)
15. Castellani "On design criteria for equipment mounted on a massive structure" V WCEE Conference , Rome 1973
16. Sing Ang "Stochastic predation of maximum seismic response of light secondary systems" paper K6/1 2 SMIRT Conference Berlin 1973
17. Biggs Roesset "Seismic Analysis of Equipment mounted on massive structures" Seismic design for Nuclear Power Plants Edited by Massive
18. Lazzeri "Floor response spectra by the use of a modified white noise technique " paper K4/2, 2 SMIRT Conf., Berlin 1973
19. Nih Chien Tsai "Spectrum compatible motions for design purposes" ASCE J. Engineering Mechanics Division Vol. 98, EM2, April 1972
20. Gasparini Van Marke "Simulated Earthquake motions compatible with prescribed response spectra" MIT Pipl. N.R76-4
21. Sachs Scanlan "Earthquake time histories and response spectra " J. Engineering Mechanics Division EM4, Aug 1974
22. Cecconi Bettocchi PhD Thesis in Civil Engineering -Univerity of Genoa 1976
23. Laguzzi e Cabella - PhD Thesis in Civil Engineerin-Univ.of Genoa 1977
24. Bisconti Lazzeri Strona "Analysis of piping for nuclear reactor Applications" Chapter 7 of Developments in stress Analysis for Press.Components
25. Stevenson Bergman "Determination of support spacing tables used in the design of safety class Nuclear plant Piping" 4 SMIRT Conf. St.Francisco 1977, K6/19
26. Lazzeri Strona "ASDIC theoretical manual " SAIGE Rep. 0226Z.

FIG. 1






FIG. 2a



building A) coupled —●— 192
 B) —x— 111
 A) —○— 192

FIG. 2b



203	156	147	138	129	120	111	102	93	84	75	66	57	48	39	30	21	12	3	1
157	148	139	130	121	112	103	94	85	76	67	58	49	40	31	22	13	4	2	
158	149	140	131	122	113	104	95	86	77	68	59	50	41	32	23	14	5		
159	150	141	132	123	114	105	96	87	78	69	60	51	42	33	24	15	6		
160	151	142	133	124	115	106	97	88	79	70	61	52	43	34	25	16	7		
161	152	143	134	125	116	107	98	89	80	71	62	53	44	35	26	17	8		
162	153	144	135	126	117	108	99	90	81	72	63	54	45	36	27	18	9		
163	154	145	136	127	118	109	100	91	82	73	64	55	46	37	28	19	10		
164	155	146	137	128	119	110	101	92	83	74	65	56	47	38	29	20	11		




FIG. 3a




FIG. 3b

MODEL




Fig. 4a

HORIZONTAL DISPLACEMENTS




Fig. 4b

SHEAR STRESS




Fig. 4c

VERTICAL STRESS




Fig. 4d




FIG. 5




FIG. 6




FIG. 7

Leere Seite
Blank page
Page vide